Product Environmental Profile

Acti 9 iATL24








General information						
Representative product	Acti 9 iATL24 - A9C15424					
Description of the product	Acti 9 iATL24 consists in 18 mm DIN mounted product to be associated to a contactor (Acti 9 iCT range) or an impulse relay (Acti 9 iTL range) with yellow clips which mechanically fixed the products together and feed, electrically speaking, the adjacent actuator.					
Functional unit	The main purpose of iATL24 is to allows control and indication of a 230 V AC contactor or impulse relay from the Acti 9 Smartlink or by a PLC, by 24 V DC signals, it also allows control by a maintained/pulse signal. The reference lifetime of 10 years					

Constituent materials



Substance assessment

Products of this range are designed in conformity with the requirements of the RoHS directive (European Directive 2011/65/EU of 8 June 2011) and do not contain, or only contain in the authorised proportions, lead, mercury, cadmium, hexavalent chromium or flame retardants (polybrominated biphenyls - PBB, polybrominated diphenyl ethers - PBDE) as mentioned in the Directive


Details of ROHS and REACH substances information are available on the Schneider-Electric Green Premium website http://www2.schneider-electric.com/sites/corporate/en/products-services/green-premium/green-premium.page

Additional environmental information

	The Acti 9 iATL24 presents the following relevent environmental aspects				
Manufacturing	Manufactured at a Schneider Electric production site ISO14001 certified				
Distribution	Weight and volume of the packaging optimized, based on the European Union's packaging directive				
Distribution	Packaging weight is 17.2 g, consisting of cardboard (60%), paper(40%)				
Installation	Ref A9C15424 does not require any installation operations				
Use	The product does not require special maintenance operations.				
	End of life optimized to decrease the amount of waste and allow recovery of the product components and materials				
	This product contains electronic card (13.7g) that should be separated from the stream of waste so as to optimize end- of-life treatment.				
End of life	The location of these components and other recommendations are given in the End of Life Instruction document which is available on the Schneider-Electric Green Premium website				
	http://www2.schneider-electric.com/sites/corporate/en/products-services/green-premium/green-premium.page				
	Recyclability potential:61%Based on "ECO'DEEE recyclability and recoverability calculation method" (version V1, 20 Sep. 2008 presented to the French Agency for Environment and Energy Management: ADEME).				

O Environmental impacts

Reference life time	10 years							
Product category	Other equipments - Active product							
Installation elements	No special components needed							
Use scenario	The product is in active mode 0.1% of the time with a power use of 18.4W and in Sleep mode 99.9% of the time with a power use of 0.8W for 10 years. And the duration of the operating modes expressed as a percentage of the full cycle time.							
Geographical representativeness	Europe							
Technological representativeness	Acti 9 iATL24 consists in 18 mm DIN mounted product to be associated to a contactor (Acti 9 iCT range) or an impulse relay (Acti 9 iTL range) with yellow clips which mechanically fixed the products together and feed, electrically speaking, the adjacent actuator.							
	Manufacturing		Installation		Use		End of life	
Energy model used	Energy model used: Spain		Electricity grid mix; AC; consumption mix, at consumer; < 1kV; EU-27		Electricity grid mix; AC; consumption mix, at consumer; < 1kV; EU-27		Electricity grid mix; AC; consumption mix, at consumer; < 1kV; EU-27	
			consumer	; < 1kV; EU-27	consumer; <	1kV; EU-27		
Compulso	ry indicators			; < 1kV; EU-27 4 - A9C15424	consumer; <	1kV; EU-27		
Compulso Impact indicators		Unit		, ,	consumer; < Distribution	1kV; EU-27 Installation		
· · · ·	ry indicators		Acti 9 iATL24	4 - A9C15424			EU	-27
Impact indicators	ry indicators depletion	Unit	Acti 9 iATL24 Total	4 - A9C15424 Manufacturing	Distribution	Installation	EU Use	-27 End of Life
Impact indicators Contribution to mineral resources	ry indicators depletion acidification	Unit kg Sb eq	Acti 9 iATL24 Total 9.16E-04	4 - A9C15424 Manufacturing 9.13E-04	Distribution 0*	Installation 0*	EU Use 3.05E-06	-27 End of Life 0*
Impact indicators Contribution to mineral resources Contribution to the soil and water	ry indicators depletion acidification	Unit kg Sb eq kg SO ₂ eq	Acti 9 iATL24 Total 9.16E-04 1.49E-01	4 - A9C15424 Manufacturing 9.13E-04 2.78E-03	Distribution 0* 4.59E-05	Installation 0* 0*	Use 3.05E-06 1.46E-01	-27 End of Life 0* 2.32E-05
Impact indicators Contribution to mineral resources Contribution to the soil and water Contribution to water eutrophication	ry indicators depletion acidification on	Unit kg Sb eq kg SO ₂ eq kg PO ₄ ³⁻ eq	Acti 9 iATL24 Total 9.16E-04 1.49E-01 9.62E-03	4 - A9C15424 Manufacturing 9.13E-04 2.78E-03 7.62E-04	Distribution 0* 4.59E-05 1.06E-05	Installation 0* 0* 0*	EU Use 3.05E-06 1.46E-01 8.84E-03	-27 End of Life 0* 2.32E-05 9.51E-06
Impact indicators Contribution to mineral resources Contribution to the soil and water Contribution to water eutrophication Contribution to global warming	ry indicators depletion acidification on	Unit kg Sb eq kg SO ₂ eq kg PO ₄ ³⁻ eq kg CO ₂ eq kg CFC11	Acti 9 iATL24 Total 9.16E-04 1.49E-01 9.62E-03 3.71E+01	4 - A9C15424 Manufacturing 9.13E-04 2.78E-03 7.62E-04 2.00E+00	Distribution 0* 4.59E-05 1.06E-05 1.01E-02	Installation 0* 0* 0* 0*	EU Use 3.05E-06 1.46E-01 8.84E-03 3.51E+01	-27 End of Life 0* 2.32E-05 9.51E-06 2.67E-02
Impact indicators Contribution to mineral resources Contribution to the soil and water Contribution to water eutrophication Contribution to global warming Contribution to ozone layer deplet	ry indicators depletion acidification on	Unit kg Sb eq kg SO ₂ eq kg PO ₄ ³⁻ eq kg CO ₂ eq kg CFC11 eq	Acti 9 iATL24 Total 9.16E-04 1.49E-01 9.62E-03 3.71E+01 2.51E-06	4 - A9C15424 Manufacturing 9.13E-04 2.78E-03 7.62E-04 2.00E+00 2.26E-07	Distribution 0* 4.59E-05 1.06E-05 1.01E-02 0*	Installation 0* 0* 0* 0* 0*	EU Use 3.05E-06 1.46E-01 8.84E-03 3.51E+01 2.29E-06	-27 End of Life 0* 2.32E-05 9.51E-06 2.67E-02 9.81E-10
Impact indicators Contribution to mineral resources Contribution to the soil and water Contribution to water eutrophicati Contribution to global warming Contribution to ozone layer deplet Contribution to photochemical oxid	ry indicators depletion acidification on	Unit kg Sb eq kg SO ₂ eq kg PO ₄ ³⁻ eq kg CO ₂ eq kg CFC11 eq kg C ₂ H ₄ eq	Acti 9 iATL24 Total 9.16E-04 1.49E-01 9.62E-03 3.71E+01 2.51E-06 8.42E-03	4 - A9C15424 Manufacturing 9.13E-04 2.78E-03 7.62E-04 2.00E+00 2.26E-07 3.75E-04	Distribution 0* 4.59E-05 1.06E-05 1.01E-02 0* 3.28E-06	Installation 0* 0* 0* 0* 0*	EU Use 3.05E-06 1.46E-01 8.84E-03 3.51E+01 2.29E-06 8.04E-03	-27 End of Life 0* 2.32E-05 9.51E-06 2.67E-02 9.81E-10 2.12E-06



■ Manufacturing ■ Distribution ■ Installation ■ Use ■ End of life

Optional indicators		Acti 9 iATL2	4 - A9C15424				
Impact indicators	Unit	Total	Manufacturing	Distribution	Installation	Use	End of Life
Contribution to fossil resources depletion	MJ	4.16E+02	1.70E+01	1.41E-01	0*	3.98E+02	8.54E-02
Contribution to air pollution	m³	1.72E+03	2.07E+02	4.28E-01	0*	1.51E+03	7.55E-01
Contribution to water pollution	m³	1.75E+03	2.97E+02	1.65E+00	0*	1.45E+03	1.33E+00
Resources use	Unit	Total	Manufacturing	Distribution	Installation	Use	End of Life
Use of secondary material	kg	7.11E-04	7.11E-04	0*	0*	0*	0*
Total use of renewable primary energy resources	MJ	8.99E+01	7.94E-01	0*	0*	8.91E+01	0*
Total use of non-renewable primary energy resources	MJ	6.35E+02	2.28E+01	1.42E-01	0*	6.12E+02	1.05E-01
Use of renewable primary energy excluding renewable primary energy used as raw material	MJ	8.96E+01	4.71E-01	0*	0*	8.91E+01	0*
Use of renewable primary energy resources used as raw material	MJ	3.23E-01	3.23E-01	0*	0*	0*	0*
Use of non renewable primary energy excluding non renewable primary energy used as raw material	MJ	6.34E+02	2.18E+01	1.42E-01	0*	6.12E+02	1.05E-01
Use of non renewable primary energy resources used as raw material	MJ	1.00E+00	1.00E+00	0*	0*	0*	0*
Use of non renewable secondary fuels	MJ	0.00E+00	0*	0*	0*	0*	0*
Use of renewable secondary fuels	MJ	0.00E+00	0*	0*	0*	0*	0*
Waste categories	Unit	Total	Manufacturing	Distribution	Installation	Use	End of Life
Hazardous waste disposed	kg	2.85E+00	2.74E+00	0*	0*	1.83E-02	9.47E-02
Non hazardous waste disposed	kg	1.32E+02	8.62E-01	0*	0*	1.31E+02	0*
Radioactive waste disposed	kg	8.77E-02	3.60E-04	0*	0*	8.74E-02	0*
Other environmental information	Unit	Total	Manufacturing	Distribution	Installation	Use	End of Life
Materials for recycling	kg	5.90E-02	6.16E-03	0*	1.72E-02	0*	3.57E-02
Components for reuse	kg	0.00E+00	0*	0*	0*	0*	0*
Materials for energy recovery	kg	6.56E-03	0*	0*	0*	0*	6.56E-03
Exported Energy	MJ	5.45E-05	5.12E-06	0*	4.94E-05	0*	0*

* represents less than 0.01% of the total life cycle of the reference flow

Life cycle assessment performed with EIME version EIME v5.8.1, database version 2016-11 in compliance with ISO14044.

The use phase is the life cycle phase which has the greatest impact on the majority of environmental indicators (based on compulsory indicators).

SCHN-00504-V01.01-EN - PEP ECOPASSPORT® - Acti 9 iATL24

Please note that the values given above are only valid within the context specified and cannot be used directly to draw up the environmental assessment of an installation.

Registration number :	SCHN-00504-V01.01-EN	Drafting rules	PCR-ed3-EN-2015 04 02		
Verifier accreditation N°	VH33	Supplemented by	PSR-0005-ed2-EN-2016 03 29		
Date of issue	12/2019	Information and reference documents	www.pep-ecopassport.org		
		Validity period	5 years		
Independent verification of the declaration and data, in compliance with ISO 14025 : 2010					
Internal	External X				
The PCR review was conducted by a panel of experts chaired by Philippe Osset (SOLINNEN)					
PEP are compliant with XP C08-100-1 :2016					
The elements of the present PEP cannot be compared with elements from another program.					
Document in compliance with ISO 14025 : 2010 « Environmental labels and declarations. Type III environmental					

Schneider Electric Industries SAS

Country Customer Care Center http://www.schneider-electric.com/contact

35, rue Joseph Monier

CS 30323

declarations »

F- 92506 Rueil Malmaison Cedex RCS Nanterre 954 503 439 Capital social 896 313 776 €

www.schneider-electric.com

SCHN-00504-V01.01-EN

Published by Schneider Electric © 2019 - Schneider Electric – All rights reserved

12/2019