recto 7200

MANCHONS PREISOLES POUR CABLES DE BRANCHEMENT

NF C 33-021

RECOMMANDATIONS POUR LA MISE EN OEUVRE

PREPARATION DU CONDUCTEUR A RACCORDER :

- Couper le conducteur avec un dispositif qui n'écrase pas l'âme.
- Dénuder le conducteur sur la longueur indiquée sur le manchon.
- Brosser le conducteur à raccorder sous graisse neutre. Ne pas essuyer le conducteur ainsi nettoyé.
- Introduire le conducteur à fond dans l'alésage du manchon.

RETREINTS :

- Utiliser une presse adaptée dotée de la matrice hexagonale préconisée.
- Réaliser les rétreints dans la zone marquée à cet effet en suivant l'ordre des numéros.
- 2 rétreints de 9 mm ou 3 rétreints de 5mm de largeur d'empreinte de chaque coté du manchon.

PREINSULATED SLEEVES FOR LOW VOLTAGE CONDUCTORS

ADVICES FOR IMPLEMENTATION

PREPARATION OF THE CONDUCTOR TO CONNECT :

- Cut the conductor with a device that does not scratch the core.
- Strip the conductor over the length indicated on the sleeve.
- Brush the conductor to connect with neutral grease. Do not dry the conductor cleaned this way.
- Insert the conductor fully in the sleeve bore.

CRIMPING :

- Use a press fitted with the advised hexagonal crimping die.
- Crimp in the indicated area in the order of the numbers.
- 2 crimps of 9 mm width or 3 crimps of 5 mm width on each side of the sleeve.

16.06

MICHAUD

verso 7200

10 MANCHONS PREISOLES POUR CABLES DE BRANCHEMENT :
10 PREINSULATED SLEEVES FOR LOW VOLTAGE CONDUCTORS :

NF C 33-021

AERIEN
AERIAL
(MJPB)

CODE	DESIGNATION	CODET
K030	MJPB 6	67 32 115
K031	MJPB 6−10	67 32 116
K032	MJPB 6−16	67 32 117
K033	MJPB 6−25	67 32 118
K035	MJPB 10	67 32 101
K036	MJPB 10−16	67 32 103
K037	MJPB 10−25	67 32 105
K039	MJPB 16−16	67 32 107
K040	MJPB 16−25	67 32 109
K042	MJPB 25	67 32 111
K053	MJPB 16−35	
K054	MJPB 25−35	
K055	MJPB 35	

AERO-SOUTERRAIN
AERIAL-SUBSURFACE
(MJPBAS)

CODE	DESIGNATION	CODET
K064	MJPBAS 16−4M	
K065	MJPBAS 16−6M	
K068	MJPBAS 10−25M	67 32 122
K069	MJPBAS 10−35M	67 32 123
K070	MJPBAS 16−16M	67 32 125
K072	MJPBAS 25−16M	67 32 128
K074	MJPBAS 25−25M	67 32 129
K076	MJPBAS 25−35M	67 32 130
K078	MJPBAS 16−25M	67 32 126
K079	MJPBAS 16−35M	67 32 127

SOUTERRAIN
SUBSURFACE
(MJPBS)

CODE	DESIGNATION	CODET
K073	MJPBS 25M−25M	67 32 304
K075	MJPBS 35M−35M	67 32 306
K085	MJPBS 16M−35M	67 32 303
K086	MJPBS 25M−35M	67 32 305